

Photovoltaic Overview

Demand Side Management and Power Quality

City of Brisbane
Baylands Specific Plan

March 12, 2007

by Frederick W Nuessle, MSME
Rick Nuessle Engineering

Photovoltaics : Technologies

Crystalline Silicon – ~99% of market

Single and polycrystalline Si

n– Boron p- Phosphorous




Figure 1: Schematic diagram of SunPower's A-300 solar cell (not to scale).

Alternate PV technologies

Amorphous Silicon




Figure 1. - Amorphous silicon's random structural characteristics result in deviations like "dangling bonds." Dangling bonds provide places for electrons to recombine with holes, but this may be neutralized somewhat with hydrogen




Figure 2. - The typical amorphous silicon cell employs a p-i-n design, in which an intrinsic layer is sandwiched between a p layer and an n layer.

Other PV technologies

Ga-As Gallium Arsenide - 28 % efficient!

n- Germanium p Indium Gallium Phosphide

Cd-Te Cadmium-Telluride

Potentially cheaper but toxic, less efficient (11%)

Nano- tech - *the jury is still out*

Science and engineering in PV, other technologies

www.nextenergycorp.com | 800-600-8171

SUNPOWER



Current Standard (Crystalline

Si)
99+ % of PV market

Sunpower, Sharp, Sanyo, BP Solar etc

PV Market standard to match:

4\$ / DC watt wholesale price

Stable cost regardless of growth (!)

14-21% cell efficiency; 10-12% system

No degradation - 25 year *warranty*

PV System Electric Characteristics

Single phase 120/240 VAC

Polyphase 120/208 277/480 AC

Module string 300-500 VDC

Inverter size in kW AC or Amperes AC


Voc - Open Circuit Voltage

Isc - Short Circuit Current

Vpp - Voltage at Peak Power

Ipp - Amperes Peak Power

IV Curve ; $P = I * V = W$



Photovoltaic system types

- ◆ Grid Tied
- ◆ Grid Tied with Battery Backup
- ◆ Stand Alone
- ◆ Stand Alone hybrid
- ◆ Roof Mount, structural attachment
- ◆ Roof Mount, non-penetrating
- ◆ Ground Mount
- ◆ Tracking (single, dual axis)

kWp rating – CEC AC Watts


$$\begin{aligned} \text{kWp} &= \text{CEC rating} \\ &= \# \text{ of panels} * \text{CEC rating per} \\ &\quad \text{panel} * \text{inverter efficiency} \end{aligned}$$

Example : 100 kW AC nominal system

540 SP -210 , Xantrex PV-100208HE

$$\text{kWp} = 540 * 193.7 * 0.95 = 99.368 \text{ kW}$$


Estimated Sun Hours (ESH)



Brisbane Sun Hours

Summer = 6.7 Winter = 3.8

Average Daily Solar Energy at Southeast Water Pollution Control Plant, 750 Phelps (Jerrold)



Estimated AC kWh from 100kW Solar System in Brisbane, Ca

Summer = May 1 – Oct 31 (PG&E)

Monthly = $6.5 * 100 * 30 \text{ days} = 19,500$
kWh

Winter = Nov 1 – Apr 30 (PG&E)

Monthly = $3.8 * 100 * 30 \text{ days} = 11,400$ kWh



\$ Value of Photovoltaic kWh

PG&E avoided cost for kWh

Total Energy Rates (\$ per kWh)	
Peak Summer	\$0.31883 (R)
Part-Peak Summer	\$0.15658 (R)
Off-Peak Summer	\$0.09291 (I)
Part-Peak Winter	\$0.13796 (R)
Off-Peak Winter	\$0.10177 (I)

A6 rate structure

No demand charges

Brisbane 100 kW avoided cost value Feb 2007 PG&E A6 rate

- ◆ Summer Savings = - \$ 3,943.27
- ◆ Winter Savings = - \$ 1,465.28
- ◆ Annual avoided cost = \$ 32,541
- ◆ Cannot get credit \$ from PG&E now

Photovoltaic kWh : Long Term Valuation

1) Avoided Cost to Utility

2) REC - Renewable Energy Credits

PBI - performance based incentives

REC, PBI = "green" value of electricity

Total Value = Avoided Cost + REC
value

Net Real Time Metering

- ◆ Net metering law requires buy-sell kWh at the same rate.
- ◆ Real Time metering will be standard
- ◆ Photovoltaics reliably match real time peak values for \$ / MWh


NJCEP SREC TABLE

Range = 170\$ - 218\$ / MWh
= \$ 0.17 -0.22 / kWh

Month	Year	# SRECs Traded in Month	Monthly High (\$/MWh)	Monthly Low (\$/MWh)	Cumulative # SRECs Traded	Cumulative Weighted Average Price (\$/MWh)
Dec	2006	2750	\$260	\$110	5351	\$195.44
Nov	2006	1022	\$260	\$110	2601	\$197.85
Oct	2006	464	\$250	\$160	1579	\$205.99
Sept	2006	747	\$255	\$174	1115	\$206.08
Aug	2006	131	\$235	\$150	368	\$213.77
July	2006	237	\$240	\$150	237	\$218.60

Source : www.njcep.com

Solar Return on Investment



100 kWp ROI numbers

- ◆ installed system cost = \$ 825,000
- ◆ CEC rebate = \$ 225,000
- ◆ (or PBI = ~\$ 341,250 in 5 years)
- ◆ 30% FETC = $0.3 * 600K = \$ 180,000$
- ◆ 5 year MACRS = approx \$ 207,000
- ◆ net 5 year cost = \$ 213 K
- ◆ 5% annual rate increases
- ◆ 1st year avoided cost = \$ 32,500

25 year 100 kW PV value

- ◆ Total PG&E avoided costs = ~\$ 1.6 M
- ◆ (with 5% increases , no real time metering)
- ◆ 25 year REC Value = ?
- ◆ 25 year PBI Value = ?

$$\text{ROI, min} = \$ 1.6 \text{ M} / 213 \text{ K} = 750\%$$

Solar Advantages

Completely Modular – from 100 W - 1 MW

Simple Interconnection standards

No noise, moving parts, maintenance

Long Life (50+ years) ; no degradation

www.nextenergycorp.com | 800-600-8171

SUNPOWER

NEXTENERGY²¹

Peak output coincident with utility

DSM Demand Side Management

Energy Efficiency – Asset protection

Reduce solar system size

Lighting

HVACR


Induction Motor efficiency

Power Quality

Uninterruptible Power


Power Quality

- ◆ Reactive Power Compensation in Real Time
- ◆ Voltage Control
- ◆ Harmonic Distortion Suppression




Espec Equalizer

VOLTAGE : PHASE TO NEUTRAL from PG&E at main



POWER QUALITY EVENT - SAG 09-07-06 9:14 AM PST

Start Date/Time	End Date/Time	Duration ms	Device	Condition	Channel	Channel ID	Value
9/7/2006 12:14	14:41.0	1024	76053	Sag	Vcn	2	168.46
9/7/2006 12:14	14:15.1	200	76053	Sag	Vcn	2	183.46
9/7/2006 12:14	14:09.8	1300	76053	Sag	Vcn	2	188.6




9/07/06 POWER QUALITY EVENT : PG&E


REPORTS "CROW ON TRANSMISSION LINE"

3 SAGS IN Vcn in total of 32 seconds elapsed time at 9:14 am September 07 , 2006


1.024 ms @ 168.46 VOLTS P-N
0.200 ms @ 183.46 VOLTS P-N
1.300 ms @ 188.6 VOLTS P-N




PHASE TO NEUTRAL DURING PQ EVENT




PHASE TO PHASE DURING PQ EVENT




POWER FACTOR 08/31/06- 09/08/06




POWER FACTOR DURING PQ EVENT



HARMONICS (5th HARMONIC - VOLTAGE)




Typical Waveform of High Tech Circuit




Effect of Elspec on Chiller

Graph 1:
Effect of Chillers on Reactive Power & Current



Elsec Effect on Wind Generator Startup

Graph 2:
Typical Start-up Current & Voltage



Graph 3:
Start-up Current & Voltage w/ EQ-W

