



NOTES:

1. Select backfill material - material from excavation, free from stones or lumps exceeding 3" in greatest dimension, vegetable matter, or unsatisfactory material. (See Specifications)
2. For new streets use design structural section as shown on plans.
3. If the edge of the trench falls within 3' of the gutter, the entire pavement shall be removed.
4. If existing pavement is less than 3" thick, pavement edge shall be sawcut to full depth in lieu of grinding.

NOT TO SCALE

<b>STANDARD DETAIL</b>	<b>CITY OF BRISBANE</b> DEPARTMENT OF PUBLIC WORKS	
	<b>UTILITY TRENCH DETAIL ( BAY MUD )</b>	<b>UT-2</b>
DATE: 08/12/08		