



- * For Cast Iron Pipe, Ductile Iron Pipe, or 4", 6" and 8" Steel Pipes Use EBAA Megalug 1100 Series Restraint.
- * For PVC pipes use EBAA Mechanical Joint Restraint Series 2000.

NOT TO SCALE

**STANDARD
DETAIL**

CITY OF BRISBANE
DEPARTMENT OF PUBLIC WORKS

DATE:06/25/07

**CAPPING ACTIVE LINE
(FOR EXISTING PLAIN END PIPE)**

W-13