



1. Contractor shall submit shop drawings for the Reduced Pressure Backflow Preventor to the City Engineer for review and approval before actual installation.
2. Backflow Prevention Device shall be provided with a steel enclosure by LeMeur Welding and Manufacturing-Model #BF-99 (dark green).
3. Installation of Reduced Pressure Backflow Preventor shall meet the requirements in AWWA Standard C511-07

NOT TO SCALE

**STANDARD
DETAIL**

DATE: 06/25/07

CITY OF BRISBANE
DEPARTMENT OF PUBLIC WORKS

BACKFLOW PREVENTION DEVICE
(TYPICAL FOR ALL IRRIGATION SERVICES
AND OTHER HIGH RISK SERVICES)

W-8B